



Massachusetts Department of Environmental Protection Source Water Assessment and Protection (SWAP) Report For The Baird Center

What is SWAP?

The Source Water Assessment and Protection (SWAP) program, established under the federal Safe Drinking Water Act, requires every state to:

- ? Inventory land uses within the recharge areas of all public water supply sources;
- ? Assess the susceptibility of drinking water sources to contamination from these land uses; and
- ? Publicize the results to provide support for improved protection.

SWAP and Water Quality

Susceptibility of a drinking water source does *not* imply poor water quality. Actual water quality is best reflected by the results of regular water tests.

Water suppliers protect drinking water by monitoring for more than 100 chemicals, treating water supplies, and using source protection measures to ensure that safe water is delivered to the tap.

Prepared by the
Massachusetts Department of
Environmental Protection,
Bureau of Resource Protection,
Drinking Water Program

Date Prepared:
November, 2003

Table 1: Public Water System (PWS) Information

PWS NAME	The Baird Center
PWS Address	900 Great Outlook Way
City/Town	Plymouth, Massachusetts
PWS ID Number	4239030
Local Contact	Executive Director, Christine Coffin
Phone Number	(508) 224-8041

Well Name	Source ID#	Zone I (in feet)	IWPA (in feet)	Source Susceptibility
Well No. 1	4239030-01G	214	528	Moderate

Introduction

We are all concerned about the quality of the water we drink. Drinking water wells may be threatened by many potential sources of contamination, including septic systems, road salting, and improper disposal of hazardous materials. Citizens and local officials can work together to better protect these drinking water sources.

Purpose of this report:

This report is a planning tool to support local and state efforts to improve water supply protection. By identifying land uses within water supply protection areas that may be potential sources of contamination the assessment helps focus protection efforts on appropriate best management practices (BMPs) and drinking water source protection measures. Department of Environmental Protection (DEP) staff are available to provide information about funding and other resources that may be available to your community.

This report includes:

1. Description of the Water System
2. Discussion of Land Uses within Protection Areas
3. Recommendations for Protection
4. Attachments, including a Map of the Protection Areas

1. Description of the Water System

The well for the facility is located approximately 1,000 feet south of Ship Pond Road near the facility. Well No. 1 has a Zone I radius of 214 feet and an Interim Wellhead Protection Area (IWPA) radius of 528 feet. The IWPA provides an interim protection area for a water supply well when the actual recharge area has not been delineated. The actual recharge area to the well may be significantly larger or smaller than the IWPA. The well is located in an aquifer with a high vulnerability to contamination due to the absence of hydrogeologic barriers that can prevent contaminant migration. Please refer to the attached map of the Zone I and IWPA.

The well serving the facility has no treatment at this time. The DEP requires public water

What is a Protection Area?

A well's water supply protection area is the land around the well where protection activities should be focused. Each well has a Zone I protective radius and an Interim Wellhead Protection Area (IWPA).

- **The Zone I** is the area that should be owned or controlled by the water supplier and limited to water supply activities.
- **The IWPA** is the larger area that is likely to contribute water to the well.

In many instances the IWPA does not include the entire land area that could contribute water to the well. Therefore, the well may be susceptible to contamination from activities outside of the IWPA that are not identified in this report.

What is Susceptibility?

Susceptibility is a measure of a well's potential to become contaminated due to land uses and activities within the Zone I and Interim Wellhead Protection Area (IWPA).

suppliers to monitor the quality of the water. For current information on monitoring results and treatment, please contact the Public Water System contact person listed above in Table 1. Drinking water monitoring reporting data is also available on the web via EPA's Envirofacts website at http://www.epa.gov/enviro/html/sdwis/sdwis_query.html.

2. Discussion of Land Uses in the Protection Areas

There are a number of land uses and activities within the drinking water supply protection areas that are potential sources of contamination.

Key issues include:

1. **Inappropriate Activities in Zone I;**
2. **Private Septic Systems; and,**
3. **Athletic fields.**

The overall ranking of susceptibility to contamination for the well is moderate, based on the presence of at least one moderate threat land use or activity in the IWPA, as seen in Table 2.

1. **Zone I** – Currently, the well does not meet DEP's restrictions, which only allow water supply related activities in Zone Is. The facility's Zone I contains the access road to the school. Please note that systems not meeting DEP Zone I requirements must get DEP approval and address Zone I issues prior to increasing water use or modifying systems.

Recommendations:

- ✓ Remove all non-water supply activities from the Zone I to comply with DEP's Zone I requirements.
- ✓ Do not use or store pesticides, fertilizers or road salt within the Zone I.
- ✓ Redirect road drainage in the Zone I away from well.

2. **Private Septic Systems** – Private septic systems are potential sources for the introduction of hazardous chemicals and microbial contaminants into the aquifer.

Recommendation:

- ✓ Regularly schedule maintenance and inspections of the septic system(s) and properly dispose of hazardous waste.

Table 2: Table of Activities within the Water Supply Protection Areas

Potential Contaminant Sources	Zone I	IWPA	Threat	Comments
Parking lot, driveways & roads	Yes	Yes	Moderate	Limit road salt usage and provide drainage away from wells
Septic System	No	Yes	Moderate	See septic systems brochure in the appendix
Athletic fields	No	Yes	Moderate	Fertilizer and pesticide use

* -For more information on Contaminants of Concern associated with individual facility types and land uses please see the SWAP Draft Land Use / Associated Contaminants Matrix on DEP's website - www.state.ma.us/dep/brp/dws/.

Glossary

Zone I: The area closest to a well; a 100 to 400 foot radius proportional to the well's pumping rate. To determine your Zone I radius, refer to the attached map.

IWPA: A 400 foot to ½ mile radius around a public water supply well proportional to its pumping rate; the area DEP recommends for protection in the absence of a defined Zone I I. To determine IWPA radius, refer to the attached map.

Zone II: The primary recharge area defined by a hydrogeologic study.

Aquifer: An underground water-bearing layer of permeable material that will yield water in a usable quantity to a well.

Hydrogeologic Barrier: An underground layer of impermeable material that resists penetration by water.

Recharge Area: The surface area that contributes water to a well.

3. **Athletic Fields** – The pesticides and fertilizers used for lawn care and gardening can be transported from the ground surface down into the aquifer with storm water and excess irrigation water. The over-application or improper storage and disposal of pesticides and fertilizers could result in contamination of the aquifer.

Recommendation:

- ✓ Inform maintenance staff and contractors about the areas that are located within the IWPA of the public water supply well and instruct them to use proper storage, disposal, and application procedures with pesticides and fertilizers.

Implementing the following recommendations will reduce the system's susceptibility to contamination.

3. Protection Recommendations

Implementing protection measures and best management practices (BMPs) will reduce the well's susceptibility to contamination. The Baird Center is commended for having an approved Wellhead Protection Plan and posting signs indicating the presence of the drinking water recharge area. The Baird Center should review and adopt the key recommendations above and the following:

Priority Recommendations:

- ✓ Do not use or store pesticides, fertilizers or road salt within the Zone I.
- ✓ Redirect road and parking lot drainage in the Zone I away from well.

Zone I:

- ✓ Redirect the access road so that it no longer runs through the Zone I.
- ✓ Conduct regular inspections of the Zone I.
- ✓ Redirect road drainage in the Zone I away from the well.
- ✓ Do not use or store pesticides, fertilizers or road salt within the Zone I.
- ✓ Consider well relocation if Zone I threats cannot be mitigated.

Training and Education:

- ✓ Train staff on proper hazardous material use, disposal, emergency response, and best management practices; include custodial staff, groundskeepers, certified operator,

and food preparation staff. Post labels as appropriate on raw materials and hazardous waste.

- ✓ Incorporate groundwater education into school curriculum (K-6 and 7-12 curricula available; contact DEP for copies).

Facilities Management:

- ✓ Implement standard operating procedures regarding proper storage, use and disposal of hazardous materials. To learn more, refer to <http://www.state.ma.us/dep/bwp/dhm/files/sqgsum.pdf> for the Requirements for Small Quantity Generators.
- ✓ Implement Best Management Practices (BMPs) for the use of fertilizer, herbicides and pesticides on facility property.
- ✓ Septic system components should be located, inspected, and maintained on a regular basis.
- ✓ Concrete pads around the well casing should slope away from the well and the well casing should extend above ground.
- ✓ For utility transformers that may contain PCBs, contact the utility to determine if PCBs have been replaced. If PCBs




Figure 1: Example of how a well could become contaminated by different land uses and activities.

For More Information:

Contact Isabel Collins in DEP's Lakeville Office at (508) 946-2726 for more information and for assistance in improving current protection measures.

More information relating to drinking water and source protection is available on the Drinking Water Program web site at:

www.state.ma.us/dep/brp/dws/

Additional Documents:

To help with source protection efforts, more information is available by request or online at www.state.ma.us/dep/brp/dws/, including:

1. Water Supply Protection Guidance Materials such as model regulations, Best Management Practice information, and general water supply protection information.
2. MA DEP SWAP Strategy
3. Land Use Pollution Potential Matrix
4. Draft Land/Associated Contaminants Matrix

Copies of this assessment have been made available to the public water supplier and town boards.

are present, urge their immediate replacement. Keep the area near the transformer free of tree limbs that could endanger the transformer in a storm.

Planning:

- ✓ Work with local officials in town to include the facility IWPA in Aquifer Protection District Bylaws and to assist you in improving protection.
- ✓ Have a plan to address short-term water shortages and long-term water demands. Keep the phone number of a bottled water company readily available.

Funding:

The Department's Wellhead Protection Grant Program provides funds to assist public water suppliers in addressing Wellhead protection through local projects. Protection recommendations discussed in this document may be eligible for funding under the "Wellhead Protection Grant Program". For additional information, please refer to the attached program fact sheet. Please note: each program year the Department posts a new Request for Response for the Grant program (RFR). Other funding opportunities are described in "Grant and Loan Programs: Opportunities for Watershed Protection, Planning and Implementation" at <http://www.state.ma.us/dep/brp/mf/files/glprgm.pdf>.

These recommendations are only part of your ongoing local drinking water source protection. Citizens and community officials should use this SWAP report to spur discussion of local drinking water protection measures.

4. Attachments

- Map of the Public Water Supply (PWS) Protection Area.
- Recommended Source Protection Measures Factsheet
- Your Septic System Brochure
- Pesticide Use Factsheet
- Healthy Schools Fact Sheet
- Wellhead Protection Grant Program Fact Sheet
- Source Protection Sign Order Form